The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 15015

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0023	1.0022
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9936	0.9939
30.00	0.9873	0.9844	0.9852
40.00	0.9790	0.9743	0.9753
50.00	0.9719	0.9656	0.9664
60.00	0.9672	0.9599	0.9597
70.00	0.9668	0.9592	0.9573
80.00	0.9722	0.9651	0.9603
90.00	0.9839	0.9784	0.9695
100.00	1.0029	0.9999	0.9857
120.00	1.0641	1.0688	1.0398
140.00	1.1359	1.1464	1.1053
160.00	1.1300	1.1305	1.1062

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.503	2.499	2.501
Cross-axis Coupling (g/g)	0.16%	0.76%	0.72%