



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15018

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0026	1.0025	1.0023
10.00	1.0000	1.0000	1.0000
20.00	0.9928	0.9930	0.9935
30.00	0.9827	0.9830	0.9841
40.00	0.9716	0.9719	0.9736
50.00	0.9622	0.9620	0.9642
60.00	0.9562	0.9550	0.9573
70.00	0.9556	0.9529	0.9550
80.00	0.9624	0.9574	0.9587
90.00	0.9770	0.9692	0.9693
100.00	1.0004	0.9893	0.9877
120.00	1.0743	1.0564	1.0506
140.00	1.1524	1.1352	1.1310
160.00	1.1256	1.1220	1.1390

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.502	2.500
Cross-axis Coupling (g/g)	0.28%	0.24%	0.76%