



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15020

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0013	1.0018	1.0013
10.00	1.0000	1.0000	1.0000
20.00	0.9964	0.9948	0.9964
30.00	0.9913	0.9872	0.9911
40.00	0.9856	0.9788	0.9853
50.00	0.9807	0.9712	0.9803
60.00	0.9778	0.9658	0.9771
70.00	0.9781	0.9645	0.9772
80.00	0.9831	0.9688	0.9819
90.00	0.9934	0.9795	0.9916
100.00	1.0100	0.9978	1.0073
120.00	1.0642	1.0599	1.0582
140.00	1.1316	1.1385	1.1200
160.00	1.1333	1.1370	1.1222

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.500	2.499
Cross-axis Coupling (g/g)	0.64%	0.60%	0.32%