



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837
S/N: 15028

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0015	1.0016	1.0009
10.00	1.0000	1.0000	1.0000
20.00	0.9958	0.9955	0.9974
30.00	0.9899	0.9892	0.9937
40.00	0.9834	0.9823	0.9895
50.00	0.9781	0.9767	0.9860
60.00	0.9752	0.9736	0.9838
70.00	0.9762	0.9747	0.9840
80.00	0.9827	0.9815	0.9876
90.00	0.9951	0.9944	0.9951
100.00	1.0144	1.0144	1.0071
120.00	1.0749	1.0758	1.0462
140.00	1.1419	1.1418	1.0982
160.00	1.1253	1.1235	1.1187

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.499	2.502
Cross-axis Coupling (g/g)	0.52%	0.84%	0.20%