The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 15033

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0020	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9947	0.9944	0.9940
30.00	0.9871	0.9863	0.9853
40.00	0.9786	0.9771	0.9753
50.00	0.9710	0.9689	0.9661
60.00	0.9656	0.9629	0.9588
70.00	0.9643	0.9612	0.9556
80.00	0.9686	0.9652	0.9576
90.00	0.9791	0.9758	0.9658
100.00	0.9970	0.9940	0.9812
120.00	1.0572	1.0560	1.0355
140.00	1.1336	1.1329	1.1057
160.00	1.1394	1.1268	1.1101

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.498	2.501	2.502
Cross-axis Coupling (g/g)	0.00%	0.48%	0.24%