



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15036

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0024	1.0023
10.00	1.0000	1.0000	1.0000
20.00	0.9946	0.9933	0.9936
30.00	0.9869	0.9838	0.9843
40.00	0.9785	0.9731	0.9739
50.00	0.9713	0.9636	0.9645
60.00	0.9669	0.9568	0.9576
70.00	0.9671	0.9548	0.9553
80.00	0.9737	0.9591	0.9590
90.00	0.9874	0.9706	0.9696
100.00	1.0094	0.9903	0.9882
120.00	1.0806	1.0573	1.0521
140.00	1.1642	1.1421	1.1321
160.00	1.1478	1.1455	1.1278

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.499	2.499
Cross-axis Coupling (g/g)	0.68%	0.64%	0.20%