



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15039

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0020	1.0021	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9944	0.9941	0.9941
30.00	0.9866	0.9856	0.9855
40.00	0.9781	0.9760	0.9760
50.00	0.9710	0.9675	0.9674
60.00	0.9669	0.9614	0.9615
70.00	0.9676	0.9598	0.9600
80.00	0.9750	0.9642	0.9647
90.00	0.9893	0.9754	0.9765
100.00	1.0114	0.9945	0.9966
120.00	1.0788	1.0591	1.0650
140.00	1.1435	1.1372	1.1514
160.00	1.1034	1.1251	1.1468

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.501	2.502
Cross-axis Coupling (g/g)	0.12%	0.64%	0.32%