The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 15042

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0022	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9950	0.9937	0.9945
30.00	0.9879	0.9848	0.9866
40.00	0.9801	0.9749	0.9780
50.00	0.9733	0.9662	0.9707
60.00	0.9689	0.9604	0.9661
70.00	0.9685	0.9592	0.9662
80.00	0.9738	0.9645	0.9726
90.00	0.9853	0.9768	0.9858
100.00	1.0038	0.9971	1.0069
120.00	1.0637	1.0632	1.0737
140.00	1.1339	1.1377	1.1470
160.00	1.1266	1.1176	1.1238

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.502	2.499
Cross-axis Coupling (g/g)	0.48%	0.32%	0.60%