



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15043

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0014	1.0023	1.0022
10.00	1.0000	1.0000	1.0000
20.00	0.9960	0.9935	0.9937
30.00	0.9902	0.9841	0.9846
40.00	0.9838	0.9735	0.9742
50.00	0.9783	0.9638	0.9647
60.00	0.9748	0.9565	0.9574
70.00	0.9749	0.9538	0.9545
80.00	0.9801	0.9569	0.9573
90.00	0.9908	0.9669	0.9667
100.00	1.0081	0.9846	0.9839
120.00	1.0640	1.0450	1.0440
140.00	1.1302	1.1157	1.1220
160.00	1.1228	1.0970	1.1251

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.499	2.500
Cross-axis Coupling (g/g)	0.32%	0.64%	0.12%