The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 15048

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0020	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9951	0.9945	0.9941
30.00	0.9880	0.9866	0.9856
40.00	0.9801	0.9779	0.9762
50.00	0.9731	0.9704	0.9678
60.00	0.9683	0.9656	0.9619
70.00	0.9672	0.9654	0.9605
80.00	0.9714	0.9713	0.9650
90.00	0.9814	0.9840	0.9762
100.00	0.9979	1.0046	0.9949
120.00	1.0521	1.0711	1.0567
140.00	1.1156	1.1486	1.1289
160.00	1.1087	1.1370	1.1166

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.501	2.502
Cross-axis Coupling (g/g)	0.08%	0.44%	0.32%