The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 15057

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0015	1.0021	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9958	0.9941	0.9951
30.00	0.9897	0.9857	0.9881
40.00	0.9828	0.9763	0.9802
50.00	0.9767	0.9679	0.9733
60.00	0.9725	0.9622	0.9686
70.00	0.9717	0.9610	0.9679
80.00	0.9759	0.9662	0.9728
90.00	0.9855	0.9784	0.9839
100.00	1.0019	0.9990	1.0026
120.00	1.0576	1.0690	1.0662
140.00	1.1336	1.1586	1.1523
160.00	1.1556	1.1592	1.1732

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.503	2.501
Cross-axis Coupling (g/g)	0.20%	0.16%	0.44%