



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15059

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0020	1.0018	1.0022
10.00	1.0000	1.0000	1.0000
20.00	0.9944	0.9949	0.9939
30.00	0.9864	0.9874	0.9852
40.00	0.9775	0.9791	0.9753
50.00	0.9697	0.9718	0.9666
60.00	0.9644	0.9668	0.9604
70.00	0.9635	0.9659	0.9588
80.00	0.9688	0.9707	0.9636
90.00	0.9809	0.9820	0.9757
100.00	1.0009	1.0012	0.9965
120.00	1.0675	1.0670	1.0688
140.00	1.1489	1.1575	1.1663
160.00	1.1441	1.1819	1.1765

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.501	2.499
Cross-axis Coupling (g/g)	0.16%	0.48%	0.04%