



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15066

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0017	1.0022
10.00	1.0000	1.0000	1.0000
20.00	0.9950	0.9953	0.9939
30.00	0.9878	0.9887	0.9851
40.00	0.9796	0.9814	0.9752
50.00	0.9723	0.9754	0.9663
60.00	0.9671	0.9718	0.9599
70.00	0.9658	0.9725	0.9579
80.00	0.9700	0.9790	0.9619
90.00	0.9803	0.9919	0.9729
100.00	0.9981	1.0123	0.9918
120.00	1.0595	1.0765	1.0564
140.00	1.1443	1.1473	1.1364
160.00	1.1691	1.1275	1.1308

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.499	2.499
Cross-axis Coupling (g/g)	0.04%	0.08%	0.40%