



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15070

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0022	1.0020	1.0024
10.00	1.0000	1.0000	1.0000
20.00	0.9940	0.9944	0.9933
30.00	0.9854	0.9863	0.9837
40.00	0.9763	0.9773	0.9731
50.00	0.9687	0.9694	0.9638
60.00	0.9644	0.9641	0.9575
70.00	0.9654	0.9633	0.9563
80.00	0.9737	0.9688	0.9621
90.00	0.9896	0.9814	0.9757
100.00	1.0146	1.0027	0.9984
120.00	1.0940	1.0759	1.0763
140.00	1.1878	1.1757	1.1800
160.00	1.1846	1.1893	1.1933

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.503	2.502	2.499
Cross-axis Coupling (g/g)	0.92%	0.20%	0.08%