



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15075

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0017	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9945	0.9951	0.9947
30.00	0.9868	0.9882	0.9871
40.00	0.9782	0.9807	0.9790
50.00	0.9709	0.9744	0.9723
60.00	0.9663	0.9708	0.9687
70.00	0.9662	0.9715	0.9699
80.00	0.9726	0.9782	0.9780
90.00	0.9859	0.9914	0.9935
100.00	1.0075	1.0121	1.0177
120.00	1.0783	1.0780	1.0949
140.00	1.1643	1.1562	1.1865
160.00	1.1563	1.1553	1.1763

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.499	2.500
Cross-axis Coupling (g/g)	0.32%	0.20%	0.08%