



# REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

**Reftek Systems Inc. purchased the REF TEK product line in May 2020.**

**Reftek Systems will honour existing product warranties and extended warranties.**

**ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:**

**Sales & Administrative:** [sales@reftek.com](mailto:sales@reftek.com)

**Support & Engineering:** [support@reftek.com](mailto:support@reftek.com)

**Accounting:** [accounting@reftek.com](mailto:accounting@reftek.com)

**Address:** 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

**Phone:** +1-902-444-7650

**Fax:** +1-902-444-7651



Refraction Technology, Inc.  
1600 Tenth Street, Suite A  
Plano, Texas 75074

<http://www.reftek.com> Tel: 214-440-1265 Fax: 972-578-0045

## 151-30A Observer Parameters Table

Seismometer Serial Number	Component	Period (sec)	Damping Coefficient	Output Voltage Sensitivity (V/m/s)	Calibration Sensitivity (m/s <sup>2</sup> /A)
G11301VS	Vertical	30.0	0.696	2001.72	10.2392
	North/South	30.2	0.700	1991.86	9.9410
	East/West	30.1	0.702	1999.66	9.8438

**Zeros: 2 radians**

$$z1 = 0$$

$$z2 = 0$$

**Poles: 4 radians**

$$p1 = -0.14810 + 0.14810i$$

$$p2 = -0.14810 - 0.14810i$$

$$p3 = -222.11 + 222.11i$$

$$p4 = -222.11 - 222.11i$$