

DATE: 2024/11/15

REF TEK 147A-01/3 Accelerometer

S/N: 24768

P/N: R-97499-00

NORMALIZED MAGNITUDE - FREQUENCY CHARACTERISTICS

Freq. (Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0003	1.0003	1.0003
10.00	1.0000	1.0000	1.0000
20.00	0.9990	0.9993	0.9992
30.00	0.9976	0.9982	0.9980
40.00	0.9958	0.9970	0.9966
50.00	0.9942	0.9959	0.9953
60.00	0.9929	0.9953	0.9944
70.00	0.9924	0.9954	0.9943
80.00	0.9930	0.9968	0.9954
90.00	0.9953	0.9996	0.9980
100.00	0.9994	1.0042	1.0024
120.00	1.0156	1.0206	1.0185
140.00	1.0445	1.0477	1.0453
160.00	1.0789	1.0765	1.0738

SENSITIVITIES

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.499	2.499
Cross-axis Coupling (g/g)	0.36%	0.84%	0.32%

* g = 9.80 m/s²

Rev H (2020-04)